

Planning Division  
15151 E. Alameda Parkway, Ste. 2300  
Aurora, Colorado 80012  
303.739.7250



August 21, 2018

Mark Paiz  
Q3 Consulting.com  
11817 Phoebe Street  
Parker, Co 80134

**Re: Telecom Facility Co-locate at Harvest and Alexander**  
Case Number: 2018-6033-00

Dear Mr. Paiz:

Thank you for your initial submission for the above named minor amendment. We reviewed it and have the following comment:

- A. **Civil Engineering** Kristin Tanabe 303-739-7306 [ktanabe@auroragov.org](mailto:ktanabe@auroragov.org)
1. Please remove AutoCad SHX text items in the comment section. Please flatten to reduce select-ability of the items.
  2. Dirt access roads are not permitted. Access roads need to be constructed of all-weather surface material.
  3. Please show grading for the access road. Erosion control measures need to be shown
- B. **Real Property** Darren Akrie 303-739-1331 [dakrie@auroragov.org](mailto:dakrie@auroragov.org)
1. Comments have not been received from Real Property. Comments will be e-mailed to you once they have been received.

Please resubmit your work with the requested change. You may email it directly to me at [wbarrett@auroragov.org](mailto:wbarrett@auroragov.org) . Should you have any questions you may contact me via email or by calling 303.739.7133 If you have specific questions about the above comments, please contact the person making the comments and cc me.

Sincerely,

W. David Barrett  
Sr. Planner II